CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0410:159 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621

Contact: Bob Misiuk (714) 670-3251 FAX (714) 690-7890

DESIGN: Model FireNet 4127 Analog Addressable fire alarm control unit. Automatic, manual, waterflow and

sprinkler supervisory service. Refer to the listee's data sheet for detailed product description and

operational considerations. System components:

MODULE	PART NO.	<u>DESCRIPTION</u>
FN-4127-BO	(K6002)	Control Board
FN-4127-CPA-BO	(K6001)	Front LCD Indicator Panel
FN-4127-SLC	(K6004)	Loop 3, 4 Board
FN-4127-NIC	(K6005)	Network Card
FN-PS4	(S400)	Power Supply
FN-ENC	(FN-ENC)	Enclosures
FN-ACC	(FN-ACC)	Battery/Accessory Enclosure

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances,

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed electrically and functionally

compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for

details.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be

used with audible appliances that can generate the temporal pattern signal.

NOTE: For <u>Fire Alarm Verification Feature</u> (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

10-27-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 21, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager